



Dept. of Fire and Emergency Services
 Fire Code Inspection Report
 Mobile Food Unit Program (MFU)

Inspection Date#:		File#:		
Applicant Name:	Sample Inspection Report			
Business Name:				
MFU Description:				
Inspection Status:	<input type="checkbox"/> Approved; <input type="checkbox"/> Not Approved (list reason in notes); <input type="checkbox"/> Other;			
<p>Notice: Mobile Food Units shall comply with the requirements of Section 319 of the 2018 International Fire Code. The permit applicant/permit holder is responsible for code compliance and no permit or permission is given to violate, cancel or set aside any of the provisions of this code or other applicable regulations or laws of the jurisdiction 2018 IFC 105.3.</p>				
Current Service Tags listing qualified inspection agency and the date of satisfactory inspection are required.		Pass	Fail	NA
The applicant has been provided a free online link to "Section 319 of the 2018 International Fire Code." https://codes.iccsafe.org/content/IFCComm2018 .		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Cooking equipment is protected by automatic fire extinguishing systems (319.4.1)		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Cooking equipment is protected by a kitchen exhaust hood in accordance with section 607 (319.3)		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
The exhaust system has been inspected and cleaned in accordance with Section (607.3). 6 month cycle Inspection Date:		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Fire protection systems and devices shall be maintained in accordance with Section 901.6. 6 month cycle Inspection Date:		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Portable fire extinguishers shall be provided in accordance with Section 906.4. (319.4.2)		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
LP-gas containers and fuel-gas piping systems shall be inspected annually by an approved inspection agency or a company that is registered with the U.S. Department of Transportation to requalify LP-gas cylinders, to ensure that system components are free from damage, suitable for the intended service and not subject to leaking. (319.8; 319.10.3).		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
A listed LP-gas alarm shall be installed within the vehicle in the vicinity of LP-gas system components, in accordance with the manufacturer's instructions. (319.8.5)		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Cooking oil storage tanks shall be listed for use and inspected by a qualified person. (319.7)		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CNG fuel system shall be inspected initially and every 3 years by a qualified CNG Fuel System inspector (319.10.3)		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Inspector:				

The undersigned affirms that this mobile food unit presented for inspection complies with the requirements of Section 319 of the 2018 IFC

Applicants Signature: _____; Date: _____